

Dr. K.I. Khatri
M.B.B.S., D.P.H.



Dy. Medical Officer Of Health
Surat Municipal Corporation

South West (Athwa) Zone


Besides Adarsh Bhavan
Gokulam Dairy Lane.
Athwalines, Surat
Phone No. : (0261)2663049-50

SWZ/OUT/H/ 3278
DATE : 24/01/2020

WHOM SO EVER IT MAY CONCERN

*It is certified that Chief Sanitary Inspector & Health team from South West (Athwa) Zone have inspected the **SRI SRI RAVISHANKAR VIDYA MANDIR**, Surat, Survey No.309/1, Village, Abhwa, Tal. Choryasi, Surat . Dt.24/01/2020 and found that School has safe drinking water facilities for the students and members of staff and is maintaining hygienic sanitation condition in the building & the campus as per the norms prescribed by the Central/State/U.T. Govt.*

This certificate is valid for one year from the date of issue. If there is any negligence from the part of institution about hygiene & sanitation it will be automatically cancelled.


Dy. Medical Officer Of Health
South West (Athwa) Zone
Surat Municipal Corporation

To,
Sri Sri Ravishankar Vidya Mandir
Survey No.309/1,
Village, Abhwa,
Surat



Public Health Laboratory

3rd Floor, Ambedkar Shopping Centre,
Nr. Mandarwaja Fire Station,
Ring Road Surat - 2
Phone No. (0261) 2337421

Name And Address of Party	Sri Sri Ravisankar Vidhyamandir, Surat Survey no. 309/1, Village Abhwa, Ta- Choryasi, Surat	Report No. PHL/WC/ 1286 /2019-2020	
		Date of Receipt of Sample	20/12/2019
Type of Sample:-	Private		
Source of the Water:-	R.O. Water		

Water Sample Test Report

Sr. No.	Quality Characteristic Test	Result	Prescribed Standards a per IS 10500:2012
1.	Turbidity	Clear	Max. 1 NTU.
2.	Taste	Agreeable	Agreeable.
3.	Free Residual Chlorine	Absent	Max. 0.2mg/lit.
4.	Odour	Agreeable	Agreeable.
5.	pH Value	7.7	6.5 To 8.5.
6.	Ammonia (as Total Ammonia-N)	Absent	Max. 0.5mg/lit.
7.	Nitrate (as NO ₃)	Absent	Max. 45mg/lit.
8.	Chlorides (as Cl)	07.0	Max. 250mg/lit
9.	Total Alkalinity (as Calcium Carbonate)	15.0	Max. 200mg/lit
10.	Total Hardness (as CaCO ₃)	15.0	Max. 200mg/lit
11.	Total Dissolved Solids	40.0	Max. 500mg/lit

Opinion: -The Sample is FIT for drinking Purpose, With Respect to the Tests Performed above.

Date: - 24-12-2019



[Signature]
Food Analyst
Surat Municipal Corporation
Surat

Note:-

- ❖ Sampling is not carried out by our authority therefore, the result contained on this report relate only to the sample material tested.
- ❖ Sample drawn by party. Report is meant for guidance only. It is not valid for any litigation or Publicity purpose.